

SM-30 SWITCH MODULE

SM-30 MOD XX					
NC	C	NO	NO	C	NC
1	2	3	4	5	6

NOTES:

1. CONTACTS SHOWN IN NORMAL POSITION OF THE SELECTOR SWITCH.
2. USED FOR ISOLATION OF HALON SYSTEM CONTROLS, ELEVATOR RECALL, DAMPER CLOSERS, BELL/STROBE BY-PASS, A/C UNIT SHUTDOWN, DOOR HOLDER BY-PASS, AND TO KEEP ANY OTHER DEVICES FROM OPERATING WHEN TESTING SMOKE DETECTORS.

**LBNL ELECTRICAL STANDARDS
FIRE ALARM SYSTEM
SM-30 SWITCH MODULE**

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	NTS
DRAWING NO. FA146	SHEET
PROJECT NO.	